

# A Hotel in Atlanta Reduces Electrical Use by 583,000 kWh and Water Use by 2.6 Million Gallons



## INTRODUCTION

The Southeast region of the United States experienced a severe drought in the recent past that highlighted the need for Atlanta businesses to implement sustainability measures to reduce water consumption.

The Hotel Engineering Team proactively initiated a plan to identify areas for improvement in HVAC operations that would lead to reduced water and electrical consumption. The team engaged Nalco Water in the process.

## PROGRAM

Two projects were identified as having fast payback and immediate positive effects.

The cooling tower project included installing new water treatment

program control equipment, and Nalco Water 3D TRASAR™ technology was chosen. 3D TRASAR technology improves program control, data capture and brings 24/7 monitoring, alarm and communication capability with the Nalco Water 360 Service option.

## RESULTS

Improved control allowed the tower blowdown to be reduced to save water. Tower cycles increased from an average of four cycles of concentration to nine. This improvement reduced tower blowdown by 2.6 million gallons annually on the main HVAC tower system, which is a \$26,200 savings in water costs based on local costs of \$10.00 per thousand gallons.

### CUSTOMER IMPACT

Annual reduction of 1,157 kWh per year per coil



### ECONOMIC RESULTS

Annual savings of \$23,325

Increase cooling tower cycles from 4 to 9 which reduced tower blowdown by 2.6 million gallons of water annually



Annual savings is \$26,200

*eROI is our exponential value: the combined outcomes of improved performance, operational efficiency and sustainable impact delivered through our services and programs.*

The second project was to clean the AHU coils in the guestrooms and install high-efficiency filters. The Nalco Water COIL-FLO™ program was chosen for its simple, safe and sustainable approach. The COIL-FLO program uses patented self-contained technology to effectively clean coils using a minimal amount of water for cleaning. This reduces clean up time and allows fast turn-around per room.

Performance metrics both before and after cleaning were measured, and new high-efficiency air filters were installed in the AHU's. Results of the cleaning showed significant improvements in cfm throughput and temperature drop across the coil, which results in faster response to guest temperature needs. In addition the power needed to run the unit dropped by an average of 1,157 kWh per year per coil, for a \$23,325 reduction in electrical cost.

## Coil Cleaning Data

| AHU Name                    |        |       | Calculations                      |                 |
|-----------------------------|--------|-------|-----------------------------------|-----------------|
| Measured items              | Before | After |                                   |                 |
| Wind Velocity (ft/min)      | 629    | 669   | <b>BTU's before</b>               | <b>16304</b>    |
| Pressure Drop Across Coil   | 1      | 1     | <b>BTU's after</b>                | <b>26589</b>    |
| Air Temp Return (Before)    | 62     | 62    |                                   |                 |
| Air Temp Supply (After)     | 59     | 57.4  |                                   |                 |
| Temperature Drop            | 3      | 4.6   |                                   |                 |
| Calculated Air Flow (cfm)   | 5032   | 5352  | <b>Energy Eff Gain %</b>          | <b>63.1</b>     |
| Duct Surface Area/Coil Area | 8      |       |                                   |                 |
| Fan Efficiency              | 85     |       | <b>Energy Saved in BTU's (hr)</b> | <b>10285</b>    |
| Cost of Electricity         | 0.04   |       |                                   |                 |
| Hours of Operation          | 1800   |       | <b>Overall Savings (kW/yr)</b>    | <b>1157</b>     |
|                             |        |       |                                   |                 |
| Refrigerant Valve Pos'n     | ON     |       | <b>Costs Savings/year/AHU</b>     | <b>\$ 46.28</b> |
| VFD Fan (Supply)            | 100%   |       |                                   |                 |
| VFD Fan (Return)            | n/a    |       |                                   |                 |

Annual greenhouse gas emissions from 78.8 passenger vehicles  
 CO<sub>2</sub> emissions from 45,068 gallons of gasoline consumed  
 CO<sub>2</sub> emissions from 935 barrels of oil consumed  
 CO<sub>2</sub> emissions from 5.3 tanker trucks' worth of gasoline  
 CO<sub>2</sub> emissions from the electricity use of 50.1 homes for one year  
 CO<sub>2</sub> emissions from the energy use of 34.8 homes for one year  
 Carbon sequestered by 10,308 tree seedlings grown for 10 years  
 Carbon sequestered annually by 85.7 acres of pine or fir forests  
 Carbon sequestered annually by 4 acres of forest preserved from deforestation  
 CO<sub>2</sub> emissions from 16,750 propane cylinders used for home barbeques  
 CO<sub>2</sub> emissions from burning 2.2 railcars' worth of coal  
 Greenhouse gas emissions avoided by recycling 140 tons of waste instead of sending to landfill

Calculations from EPS's Carbon Footprint Reduction Calculator  
<http://www.epa.gov/cleanenergy/energy-resources/calculator.html>

### Nalco Water, an Ecolab Company

**North America:** 1601 West Diehl Road • Naperville, Illinois 60563 • USA

**Europe:** Richtstrasse 7 • 8304 Wallisellen • Switzerland

**Asia Pacific:** 2 International Business Park • #02-20 The Strategy Tower 2 • Singapore 609930

**Greater China:** 18G • Lane 168 • Da Du He Road • Shanghai China • 200062

**Latin America:** Av. Francisco Matarazzo • nº 1350 • Sao Paulo – SP Brazil • CEP: 05001-100

[nalco.ecolab.com](http://nalco.ecolab.com)